

FIXTURE COMES PARTIALLY ASSEMBLED.



Ensure electrical circuit is disconnected before installation.



Luminaires must be installed in accordance with national electrical code and local regulation.






Fig. 1

1. Attach mounting bracket to the ceiling using appropriate fasteners (not included).
2. Secure gripper to mounting bracket using the nut.
3. Pass the power over aircraft cable through the gripper.
4. Make all necessary electrical connections, lift the canopy into position and secure it with the canopy ring (see Fig. 1).

Note: The canopy is used to cover the branch circuit/junction box.




Integral Driver Installation



1. Make all necessary electrical connections.
2. Remove film from back of the driver.
3. Place driver inside the junction box.

Remote Box Installation



1. Remove the 2x 8-32 screws and the remote box cover
2. Remove the necessary knockouts
3. Attach the conduits "NOT SUPPLIED"
4. Make all necessary electrical connections
5. Re-attach the cover and secure it with the supplied screws

Use the mounting brackets to secure the box in place.