


1 OPEN PLAN OFFICE SPACE

Direct-Indirect with 800 lms/ft (65 up/35 down)


Room Size:	50'x50'	Workplane 30" above finished floor (fc level)	53
Ceiling height:	10'	Workplane uniformity max to min	1.3:1
Luminaire mounting height:	8'5"	Ceiling uniformity maximum to minimum	5:1
Reflectances:	80/50/20	*UGR average	13
Light loss factor:	1.0	Watt sq/ft	0.61



2 SINGLE OFFICE SPACE

Direct-Indirect with 1000 lms/ft (65 up/35 down)

Room Size:	10'x10'	Workplane 30" above finished floor (fc level)	34
Ceiling height:	10'	Ceiling uniformity maximum to minimum	2.7:1
Luminaire mounting height:	8'5"	*UGR average	11
Reflectances:	80/50/20	Watt sq/ft	0.68
Light loss factor:	1.0		




3 CONFERENCE ROOM

Direct-Indirect with 1000 lms/ft (65 up/35 down)

Room Size:	12'x 20'	Worl
Ceiling height:	10'	*UGI
Luminaire mounting height:	8'	Wat
Reflectances:	80/50/20	
Light loss factor:	1.0	

Workplane 30" above finished floor (fc level)	38
*UGR average	12
Watt sq/ft	0.49



^{*}In AGI32, all calculated UGR values of less than 10 are rounded to 10.