

BOGGLE™ SHORT SPECIFICATION SHEET



Fixture Type	Fixture Code	Quantities

-1	

HOW TO ORDER

1. LUMINAIRE

BGGR1R Direct

One power cord for every 50 linear feet.

2. LENGTH OF RUN

Order in 2ft increments.

SFA____

Order in 2ft increments.

3. MAX LENGTH PER SECTION

SL02 2ft 1 **SL04** 4ft **SL06** 6ft **SL08** 8ft

SL10 10ft **SL12** 12ft

4. LOUVER

BL1 White Glossy BL2 Black Glossy BL3 White Matte BL4 Black Matte

All data shown based on max values, consult Performance Data download for more details.

5. LM/FT

LPF100 1000 lm/ft

6. CRI

CR90 CRI 90+

¹ Not available with 200 lm/ft.

^{*} You can select the preferred maximum length per segment, to account for transportation and building constraints. Example: If a 40ft run is required and SL12 (12ft) is selected, we would provide 4x 10ft segments. For special requirements, please contact sales@betacalco.com.

7		
/ . '	•	.

CTA60 Tunable White 1

¹ Consult factory.

8. VOLTAGE

V1 120/277V **V2** 240V ¹ **V3** 347V ² **V4** Low Voltage ³

9. DIMMING

DA01 0-10V Dimming 1.0% **DA02** 0-10V Dimming 0.1% ¹ **DA20** DALI Dimming 0.1% ¹ **DA21** DALI Dimming 1.0% ¹

DA30 DSI/switchDim ² DA45 PoE ³

10. CEILING TYPE & TRIM

RT1 Tegular T-Bar 1 RT2 Lay-In T-Bar 1 RT3 Trimless 3 RT4 Trim

11. CEILING TRIM FINISH

FA00 Not required FA01 White 1 FA02 Black Metallic Textured 1

¹ Not available in North America.

² Only available with DA01 dimming.

³ Only available with DA45 dimming.

¹ Not available with V3.

² Not available in North America. Not available with CTA60 (Tunable white).

³ Only available with V4.

¹ Fixture designed to fit into a 9/16" or 15/16" standard tegular grid T-bar and through tile mount. Dimensions are nominal for grid ceiling fixtures. All fixture metalwork is white.

² Fixture designed to fit into a 9/16" or 15/16" standard grid T-bar and through tile mount. Dimensions are nominal for grid ceiling fixtures. All fixture metalwork is white.

³ Fixture designed for drywall ceilings.

¹ Required for RT4 only.



12. EMERGENCY

E0 Not required E1 Emergency system - Integral ¹ E3 Emergency generated circuit - Remote ¹

13. CHICAGO PLENUM

CPO Not required

CP1 Chicago Plenum 1

¹ A drawing will be required at time of ordering to determine the required number and location of the emergency sections or generator circuits. Not available in 347V. Available upon request, consult factory for details.