


FLUTE™ SHORT SPECIFICATION SHEET



Fixture Type	Fixture Code	Quantities

1 HOW TO ORDER

1. LUMINAIRE

FLUP1P Direct FLUP2P Direct/Indirect

Data shown based on max values, consult Performance Data download for more details. Non Illuminated Reveal versions available, consult factory for details.

One power cord for every 50 linear feet.

2. LENGTH OF RUN

Minimum length to order is 4ft and orders to be in 2ft increments. For 6 inch increments, consult factory.

Example: 4ft = SFA0400 Example: 10ft = SFA1000 Example: 50ft = SFA5000

For runs over 50ft in length, consult factory.

SFA____

Minimum length to order is 4ft and orders to be in 2ft increments. For 6 inch increments, consult factory.

Example: 4ft = SFA0400 Example: 10ft = SFA1000 Example: 50ft = SFA5000

For runs over 50ft in length, consult factory.



3. MAX LENGTH PER SECTION

SL04 4ft **SL06** 6ft **SL08** 8ft **SL10** 10ft

SL12 12ft

You can select the preferred maximum length per segment, to account for transportation and building constraints. Example: If a 40ft run is required and SL12 (12ft) is selected, we would provide 4 10ft segments. For special requirements, please contact sales@betacalco.com.

4. LM/FT (DIRECT)

LPF020 200 lm/ft	LPF040 400 lm/ft	LPF060 600 lm/ft	LPF080 800 lm/ft
-------------------------	-------------------------	-------------------------	-------------------------

LPF100 1000 lm/ft **LPF120** 1200 lm/ft **LPF140** 1400 lm/ft

5. LM/FT (INDIRECT)

LPG000 Not required	LPG020 200 lm/ft	LPG040 400 lm/ft	LPG060 600 lm/ft
LPG080 800 lm/ft	LPG100 1000 lm/ft	LPG120 1200 lm/ft	LPG140 1400 lm/ft

LPG165 1650 lm/ft

6. CRI

CR80 CRI 80+ CR90 CRI 90+

7. CCT - DIRECT

CTA27 2700K **CTA30** 3000K **CTA35** 3500K **CTA40** 4000K

8. CCT - INDIRECT

CTB00 Not required **CTB27** 2700K **CTB30** 3000K **CTB35** 3500K

CTB40 4000K

9. DIRECT DIFFUSER

DD2 Batwing **DD4** Comfort

10. INDIRECT DIFFUSER

UD0 Not required **UD1** Batwing **UD3** Asymmetric ¹

11. UPLIGHT BLACKOUT PLATE

UB00 Not required **UB_** Blackout plate ¹

¹ Available up to 1200 lms/ft.

¹ Available on a per foot basis. May be required to prevent lighting up duct work in a loft type application.



12. VOLTAGE

V1 120/277V **V2** 240V ¹ **V3** 347V ² **V4** Low Voltage ³

13. DIMMING

DA01 0-10V Dimming 1.0% **DA02** 0-10V Dimming 0.1% ¹ **DA20** DALI Dimming 0.1% ¹ **DA21** DALI Dimming 1.0% ¹

DA30 DSI/switchDim ² DA45 PoE ³

14. CEILING TYPE

G1 Grid ceiling ¹ H1 Hard ceiling ²

15. SUSPENSION

HLA03 3ft cable suspension HLA06 6ft cable suspension HLA09 9ft cable suspension

Special order available on lengths over 10ft and may be subject to longer lead times, consult factory.

16. FIXTURE FINISH

FA01 White FA02 Black Metallic - Textured FA20 Silver Metallic - Textured FA25 Gold Metallic - Textured

FA27 Wood grain - Light Cherry ¹ FA28 Wood grain - Dark Walnut ¹FA44 Midnight Blue Metallic - FA45 Copper Metallic

Textured

FA46 Charcoal Metallic - FA47 Bronze Metallic - Textured FA52 Champagne Metallic - FA53 Red Metallic - Textured

Textured

¹ V2 not available in North America.

² V3 available with DA01 dimming only.

³ V4 available with DA45 dimming only.

¹ Not available with V3.

² Not available in North America.

³ Only available with V4.

¹ Combo kit includes installation to T-bar and through tile mount.

² Designed for drywall ceilings.

¹ Longer than normal lead times may apply, consult factory.



17. CANOPY FINISH

CF01 White **CF02** Black Metallic - Textured **CF20** Silver Metallic - Textured CF25 Gold Metallic - Textured

CF46 Charcoal Metallic -CF44 Midnight Blue Metallic -CF45 Copper Metallic

CF53 Red Metallic - Textured

CF47 Bronze Metallic - Textured

Textured Textured

18. EMERGENCY

CF52 Champagne Metallic

EO Not required E1 Emergency system - Integral 1 E3 Emergency generated circuit 1

19. CIRCUITS

CS1 Single circuit CS4 Emergency generated CS2 Dual circuit 1

circuit 1

20. SENSORS

Compatible with Avi-On, Casambi, Enlighted, Lutron Vive, nLight, NX Lighting Controls, Osram, Philips, and others. Consult factory.

¹ A drawing will be required at the time of ordering to determine the required number and location of the emergency sections or generator circuits. Not available in 347V.

¹ Only required if ordering Emergency system.