C LE LOUVRE[™] SHORT SPECIFICATION SHEET



Fixture Type

Fixture Code

Quantities

LE LOUVRE[™] – SUSPENDED CONTINUOUS SHORT SPECIFICATION SHEET

HOW TO ORDER

1. LUMINAIRE

LELP1P Direct

LELP2P Direct/Indirect

One power cord for every 50 linear feet.

2. LENGTH OF RUN

The minimum length of order is 4ft. Lengths are to be in 2ft increments.

Example: 4ft = SFA040 Example: 10ft = SFA100 Example: 50ft = SFA500

For runs over 50ft in length, consult factory.

SFA___

The minimum length of order is 4ft. Lengths are to be in 2ft increments.

Example: 4ft = SFA040 Example: 10ft = SFA100 Example: 50ft = SFA500

For runs over 50ft in length, consult factory.

3. MAX LENGTH PER SECTION

SLO4 4ft	SLO6 6ft	SL08 8ft	SL10 10ft
SL12 12ft			

You can select the preferred maximum length per segment, to account for transportation and building constraints. Example: If a 40ft run is required and SL12 (12ft) is selected, we would provide 4 10ft segments. For special requirements, please contact sales@betacalco.com.

4. LOUVER

LV1 Frosted	LV2 Black	LV4 Satin Chrome	LV6 Satin Gold
LV9 Satin Champagne			

Refer to the performance data for the output specifications of each louver option.

5. LM/FT (DIRECT)

LPF010 100 lm/ft	LPF020 200 lm/ft	LPF030 300 lm/ft	LPF040 400 lm/ft
LPF050 500 lm/ft	LPF060 600 lm/ft	LPF070 700 lm/ft	LPF080 800 lm/ft
LPF100 1000 lm/ft	LPF120 1200 lm/ft		

Lumens/ft are determined by the color of the Louver. Consult website for available lumens/ft. based on selected louver.

6. LM/FT (INDIRECT)

LPG000 Not required LPG100 1000 lm/ft	LPG025 250 lm/ft LPG120 1200 lm/ft	LPG050 500 lm/ft LPG160 1600 lm/ft	LPG075 750 lm/ft
Consult website for available lumens/ft. All data shown based on DD3 diffuser.			
7. CRI			
CR80 CRI 80+	CR90 CRI 90+		
8. CCT (DIRECT)			
CTA27 2700K	CTA30 3000K	CTA35 3500K	CTA40 4000K
9. CCT (INDIRECT)			
CTB00 Not required CTB40 4000K	СТВ27 2700К	СТВЗО 3000К	CTB35 3500K

10. DIRECT DIFFUSER

DD1 Asymmetric diffuser ¹ DD4 Comfort diffuser

¹ Recommended for use with Frosted louver only. When standing at the end view of the profile on the side where the power cord is installed, the asymmetric beam will aim to the right.

11. UPLIGHT DIFFUSER

UD0 Not required

UD1 Batwing

UD3 Asymmetric diffuser ¹

¹ Available up to 1200 lm/ft.

LE LOUVRE[™] - SUSPENDED CONTINUOUS SHORT SPECIFICATION SHEET

12. BLACKOUT PLATE

UB00 Not required UB__ Blackout plate ¹

¹ Available on a per foot basis. May be required to prevent lighting up duct work in a loft type application.

13. VOLTAGE			
V1 120/277V	V2 240V ¹	V3 347V ²	V4 Low Voltage ³
¹ Not available in North America			
² Only available with DA01 dimm	ning.		
³ Only available with DA45 dimn	ning.		
14. DIMMING			
DA01 0-10V Dimming 1.0%	DA02 0-10V Dimming 0.1% ¹	DA20 DALI Dimming 0.1% ¹	DA21 DALI Dimming 1.0% ¹
DA30 DSI/switchDim ²	DA45 PoE ³		
¹ Not available with 347V.			
² Not available in North America.			
³ Only available with V4.			

15. CEILING TYPE

G1 Grid ceiling ¹ H1 Hard ceiling ²

The cost for the canopies, power cables, connections mechanisms and endcaps for the fixture has been added to these items.

¹ Combo kit provided includes installation to T-bar and through tile mount.

² Designed for drywall ceilings.

16. SUSPENSION

HLA03 3ft cable suspension

HLA06 6ft cable suspension

HLA09 9ft cable suspension

17. FIXTURE FINISH

FA01 White - Textured	FA02 Black Metallic - Textured	FA20 Silver Metallic - Textured	FA25 Gold Metallic - Textured
FA27 Wood grain - Light Cherry	¹ FA28 Wood grain - Dark Walnut	1 FA44 Midnight Blue Metallic -	FA45 Copper Metallic
	-	Textured	
FA46 Charcoal Metallic -	FA47 Bronze Metallic - Textured	FA52 Champagne Metallic	FA53 Red Metallic - Textured
Textured			

¹ Longer than normal lead times may apply, consult factory.

18. CANOPY FINISH

CF01 White	CF02 Black Metallic - Textured	CF20 Silver Metallic - Textured	CF25 Gold Metallic - Textured
CF44 Midnight Blue Metallic -	CF45 Copper Metallic	CF46 Charcoal Metallic -	CF47 Bronze Metallic - Textured
Textured		Textured	
CF52 Champagne Metallic	CF53 Red Metallic - Textured		

19. EMERGENCY

E0 Not required E1 Emergency system - Integral ¹ E3 Emergency generator circuit ¹

¹ A drawing will be required at the time of ordering to determine the required number and location of the emergency sections or generator circuits. ¹ Available upon request, consult factory for details. Not available with 347V.

20. CIRCUITS

CS1 Single circuit CS2 Dual circuit ¹

¹ Independent control of uplight for LELP2P.

21. SENSORS

Compatible with Avi-On, Casambi, Enlighted, Lutron Vive, nLight, NX Lighting Controls, Osram, Philips, and others. Consult factory.