

LE LOUVRE™ - CONTINUOUS



Project Name:

Fixture Type:

Fixture Code:

Quantities:

A. LUMINAIRE

LELP1P Direct

LELP2P Direct/Indirect

One power cord for every 50 linear feet.

B. LENGTH OF RUN

SFA _ _ _

The minimum length of order is 4ft. Lengths are to be in 2ft increments.

Example: 4ft = SFA040

Example: 10ft = SFA100

Example: 50ft = SFA500

For runs over 50ft in length, consult factory.

C. MAX LENGTH PER SECTION

SL04 4ft

SL06 6ft

SL08 8ft

SL10 10ft

SL12 12ft

You can select the preferred maximum length per segment, to account for transportation and building constraints. Example: If a 40ft run is required and SL12 (12ft) is selected, we would provide 4 10ft segments. For special requirements, please contact sales@betacalco.com.

D. LOUVER

LV1 Frosted

LV2 Black

LV4 Satin Chrome

LV6 Satin Gold

LV9 Satin Champagne

E. LM/FT (DIRECT)

LPF010 100 lm/ft

LPF020 200 lm/ft

LPF030 300 lm/ft

LPF040 400 lm/ft

LPF050 500 lm/ft

LPF060 600 lm/ft

LPF070 700 lm/ft

LPF080 800 lm/ft

LPF100 1000 lm/ft

LPF120 1200 lm/ft

Lumens/ft are determined by the color of the Louver. Consult website for available lumens/ft. based on selected louver.

F. LM/FT (INDIRECT)

LPG000 Not required

LPG025 250 lm/ft

LPG050 500 lm/ft

LPG075 750 lm/ft

LPG100 1000 lm/ft

LPG120 1200 lm/ft

LPG160 1600 lm/ft

Consult website for available lumens/ft.
All data shown based on DD3 diffuser.

G. CRI

CR80 CRI 80+

CR90 CRI 90+

H. CCT (DIRECT)

CTA27 2700K

CTA30 3000K

CTA35 3500K

CTA40 4000K

LE LOUVRE™ - CONTINUOUS

I. CCT (INDIRECT)

CTB00 Not required
CTB40 4000K

CTB27 2700K

CTB30 3000K

CTB35 3500K

J. DIRECT DIFFUSER

DD1 Asymmetric diffuser ¹

DD4 Comfort diffuser

¹ Recommended for use with Frosted louver only. When standing at the end view of the profile on the side where the power cord is installed, the asymmetric beam will aim to the right.

K. UPLIGHT DIFFUSER

UD0 Not required

UD1 Batwing

UD3 Asymmetric diffuser ¹

¹ Available up to 1200 lm/ft.

L. BLACKOUT PLATE

UB00 Not required

UB_ _ Blackout plate ¹

¹ Available on a per foot basis. May be required to prevent lighting up duct work in a loft type application.

M. VOLTAGE

V1 120/277V

V2 240V ¹

V3 347V ²

V4 Low Voltage ³

¹ Not available in North America.

² Only available with DA01 dimming.

³ Only available with DA45 dimming.

N. DIMMING

DA01 0-10V Dimming 1.0%

DA02 0-10V Dimming 0.1% ¹

DA20 DALI Dimming 0.1% ¹

DA21 DALI Dimming 1.0% ¹

DA30 DSI/switchDim ²

DA45 PoE ³

¹ Not available with 347V.

² Not available in North America.

³ Only available with V4.

O. CEILING TYPE

G1 Grid ceiling ¹

H1 Hard ceiling ²

The cost for the canopies, power cables, connections mechanisms and endcaps for the fixture has been added to these items.

¹ Combo kit provided includes installation to T-bar and through tile mount.

² Designed for drywall ceilings.

P. SUSPENSION

HLA03 3ft cable suspension

HLA06 6ft cable suspension

HLA09 9ft cable suspension



LE LOUVRE™ - CONTINUOUS

Q. FIXTURE FINISH

FA01 White - Textured	FA02 Black Metallic - Textured	FA20 Silver Metallic - Textured	FA25 Gold Metallic - Textured
FA27 Wood grain - Light Cherry ¹	FA28 Wood grain - Dark Walnut ¹	FA44 Midnight Blue Metallic - Textured	FA45 Copper Metallic
FA46 Charcoal Metallic - Textured	FA47 Bronze Metallic - Textured	FA52 Champagne Metallic	FA53 Red Metallic - Textured

¹ Longer than normal lead times may apply, consult factory.

R. CANOPY FINISH

CF01 White	CF02 Black Metallic - Textured	CF20 Silver Metallic - Textured	CF25 Gold Metallic - Textured
CF44 Midnight Blue Metallic - Textured	CF45 Copper Metallic	CF46 Charcoal Metallic - Textured	CF47 Bronze Metallic - Textured
CF52 Champagne Metallic	CF53 Red Metallic - Textured		

S. EMERGENCY

E0 Not required	E1 Emergency system - Integral ¹	E3 Emergency generator circuit ¹
------------------------	--	--

¹ A drawing will be required at the time of ordering to determine the required number and location of the emergency sections or generator circuits. ¹ Available upon request, consult factory for details. Not available with 347V.

T. CIRCUITS


CS1 Single circuit	CS2 Dual circuit ¹
---------------------------	--------------------------------------

¹ Independent control of uplight for LELP2P.


U. SENSORS

LE LOUVRE™ - CONTINUOUS

DIMENSIONAL DIAGRAMS



LE LOUVRE™ - CONTINUOUS



Canopy with Sensor

Standard Canopy